

Optional Information

Name of School:

Date of Inspection:

Vocational Program/Course/Room:

Signature of Inspector:

**Fixed Ladders
Self Inspection Checklist**

Guidelines: This checklist covers some of the regulations issued by the U.S. Department of Labor - OSHA under the General Industry standard 29 CFR 1910.27 which was adopted by reference. It applies to fixed ladders between the pitch range of 60 degrees to 90 degrees from the horizontal. Fixed ladders in the range of 75 degrees to 90 degrees of the horizontal are preferred. This checklist does not address fixed ladders with cages, baskets, wells, hatch covers, landing platforms, or ladders exceeding 20 feet in height (see 29 CFR 1910.27). It also does not address fixed ladders associated with construction sites (see 29 CFR 1926.1051 and 1926.1053). Consult the OSHA regulations for requirements in these situations. Any question marked with the symbol (☹) indicates a history of previous violations in vocational schools.

	<u>Please Circle</u>
1. Is the distance between rungs 12 inches or less and uniform throughout the length of the ladder? [29 CFR 1910.27(b)(1)(ii)]	Y N N/A DK
2. Is the minimum clear length of rungs or cleats at least 16 inches? [29 CFR 1910.27(b)(1)(iii)]	Y N N/A DK
3. Are the rungs, cleats and steps free of splinters, sharp edges, burrs, or other projections which may be a hazard. [29 CFR 1910.27(b)(1)(iv)]	Y N N/A DK

Comments/Corrective Action:

Safe Schools: A Health and Safety Check

New Jersey Safe Schools Program/New Jersey Department of Education

- | | | |
|--|--|------------|
| 4. | Are the rungs of ladders designed so that the foot cannot slip off the end? [29 CFR 1910.27(b)(1)(v)] | Y N N/A DK |
| 5. | Are the rungs of metal ladders at least three-fourths of inch in diameter? [29 CFR 1910.27(b)(1)(i)] | Y N N/A DK |
| <p>Note: If the ladder is embedded in concrete and serves as an access to pits and other areas under the floor that is subject to corrosion and rusting, the rungs must be at least one inch in diameter or be painted or otherwise treated to resist corrosion and rusting. [29 CFR 1910.27(b)(7)(i)]</p> | | |
| 6. | Are the rungs of wood ladders at least 1 and 1/8 of inches in diameter? [29 CFR 1910.27(b)(1)(i)] | Y N N/A DK |
| 7. | Do siderails which might be used as a climbing aid provide adequate gripping surface without sharp edges, splinters or burrs? [29 CFR 1910.27(b)(2)] | Y N N/A DK |
| 8. | Are metal ladders painted or treated to protect from corrosion and rusting when location demands? [29 CFR 1910.27(b)(7)] | Y N N/A DK |
| 9. | Are wood ladders treated with a nonirritating preservative when used under conditions where decay may occur? [29 CFR 1910.27(b)(7)] | Y N N/A DK |

Comments/Corrective Action:

Safe Schools: A Health and Safety Check

New Jersey Safe Schools Program/New Jersey Department of Education

10. Is the perpendicular distance from the center-line of the rungs to the nearest permanent object on the climbing side of the ladder 36 inches for a pitch of 76° and 30 inches for a pitch of 90°? [29 CFR 1910.27(c)(1)] Y N N/A DK

Note: The intent of this standard is to preclude the possibility of the climber bumping his or her head or shoulder on an object while climbing or descending the ladder.

11. Is the distance from the centerline of the rung, cleat, or step to the nearest permanent object in back of the ladder at least 7 inches? [29 CFR 1910.27(c)(4)] Y N N/A DK

Note: The purpose of this standard is to give adequate clearance so that the climber's foot does not strike an object between the wall and the ladder and cause a fall.

12. Is the distance from the centerline of the grab bar to the nearest permanent object in back of the grab bar at least 4 inches? [29 CFR 1910.27(c)(5)] Y N N/A DK

Note: The purpose of this standard is to ensure that the climber can quickly grab the bar and not have difficulty because the bar is too close to the wall.

Comments/Corrective Action:

Safe Schools: A Health and Safety Check

New Jersey Safe Schools Program/New Jersey Department of Education

- 13.☹ Is the step across distance from the nearest edge of the ladder to the nearest edge of the equipment or structure not more than 12 inches and not less than 2-1/2 inches? [29 CFR 1910.27(c)(6)] Y N N/A DK

Note: If the step across distance is greater than 12 inches, a landing platform of at least 24 inches in width and 30 inches in length must be provided with standard railings and toeboards. Consult the OSHA regulations 29 CFR 1910.27(d)(2) for requirements.

- 14.☹ Are the siderails of ladders extended at least 3-1/2 feet above the landing? [29 CFR 1910.27(d)(3)] Y N N/A DK

Note: The purpose of this standard is to give the climber something to hold onto while getting off and onto the ladder.

15. Are all ladders inspected regularly and maintained in a safe condition? [29 CFR 1910.27(f)] Y N N/A DK

Comments/Corrective Action:

Safe Schools: A Health and Safety Check